

TYPE CERTIFICATE



Czech

Registration number 15.598.967

issued for the manufacturer:

Tritón Pardubice, spol. s r. o.
č.p. 130
CZ - 530 02 Starý Mateřov
Company Registration No.: 60110422

for the product:

Name: **Free-standing cabinet RMA 800 kg**
Free-standing demountable rack RZA 800 kg
Type designation: **RMA-42-A88-CAX-N1**
RMA-42-A66-CAX-N1
RZA-42-A88-CAX-N1
RZA-42-A66-CAX-N1
Modification: see the annex to this certificate
Place of the production: Tritón Pardubice, spol. s r. o.,
č.p. 130, CZ - 530 02 Starý Mateřov

at which the certification has been conducted pursuant to certification scheme SCH3 – based on ISO/IEC 17067, scheme 3 and in accordance with TÜV SÜD Czech certification system. The results are stated in Evaluation report file No. 15.599.067 from 28.11.2023.

The product type mentioned above fulfils the applicable requirements of the following regulations/standards which were the basis for its evaluation:

ČSN EN 62208 ed.2:2012 (EN 62208:2011)

This certificate is valid till: **11.12.2028**

Details and validity conditions are stated in the annex which forms an integral part of this Certificate and contains 2 pages.

This certificate is issued on the basis of voluntary certification, and it does not substitute outputs of the authorized or notified body.

Prague, 12.12.2023



Head of the certification body

1. The product specimen was entered for evaluation and type certification on 09.10.2023.
2. The Certificate was issued on the basis of the documents provided by the client:
 - See inspection folder No. 15.599.067
3. The assessment of factory production control was performed at the product manufacturer concentrating on elements ensuring the continuation of product conformity with certification requirements.
4. Detailed technical data characterizing the product type:

Name: **Free-standing cabinet RMA 800 kg**
Type designation: **RMA-42-A88-CAX-N1, RMA-42-A66-CAX-N1**
Code: **RMA-xx-xxx-xxx-N1**

Modification 600 mm:

RMA-15-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RMA-18-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RMA-22-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RMA-27-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RMA-32-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RMA-37-x66/x68/x69/x51/x60/x62-xxx-Nx-xxx
RMA-42-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RMA-45-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RMA-47-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RMA-xx-x66/x68/x69/x61/x60/x62-xxx-Nxxxxx

Modification 800 mm:

RMA-15-x86/x88/x89/x81/x80/x82-xxx-Nx-xxx
RMA-18-x86/x88/x89/x81/x80/x82-xxx-Nx-xxx
RMA-22-x86/x88/x89/x81/x80/x82-xxx-Nx-xxx
RMA-27-x86/x88/x89/x81/x80/x82-xxx-Nx-xxx
RMA-32-x86/x88/x89/x81/x80/x82-xxx-Nx-xxx
RMA-37-x86/x88/x89/x81/x80/x82-xxx-Nx-xxx
RMA-42-x86/x88/x89/x81/x80/x82-xxx-Nx-xxx
RMA-45-x86/x88/x89/x81/x80/x82-xxx-Nx-xxx
RMA-47-x86/x88/x89/x81/x80/x82-xxx-Nx-xxx
RMA-xx-x86/x88/x89/x81/x80/x82-xxx-Nxxxxx



Technical parameters (for all modifications):
Maximum Capacity – 800 kg
Maximum permissible door load – 20 kg
Protection – IP20

Name: **Free-standing demountable rack RZA 800 kg**
Type designation: **RZA-42-A88-CAX-N1, RZA-42-A66-CAX-N1**
Code: **RZA-xx-xxx-xxx-N1**

Modification 600 mm:

RZA-15-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RZA-18-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RZA-22-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RZA-27-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RZA-32-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RZA-37-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RZA-42-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RZA-45-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RZA-47-x66/x68/x69/x61/x60/x62-xxx-Nx-xxx
RZA-xx-x6x-xxx-Nx-xxx

Modification 800 mm:

RZA-15-x86/x88/x89/x81 /x80/x82-xxx-Nx-xxx
 RZA-18-x86/x88/x89/x81 /x80/x82-xxx-Nx-xxx
 RZA-22-x86/x88/x89/x81 /x80/x82-xxx-Nx-xxx
 RZA-27-x86/x88/x89/x81 /x80/x82-xxx-Nx-xxx
 RZA-32-x86/x88/x89/x81 /x80/x82-xxx-Nx-xxx
 RZA-37-x86/x88/x89/x81 /x80/x82-xxx-Nx-xxx
 RZA-42-x86/x88/x89/x81 /x80/x82-xxx-Nx-xxx
 RZA-45-x86/x88/x89/x81 /x80/x82-xxx-Nx-xxx
 RZA-47-x86/x88/x89/x81 /x80/x82-xxx-Nx-xxx

RZA-xx-x8x-xxx-Nx-xxx

Technical parameters (for all modifications):

Maximum Capacity - 800 kg

Maximum permissible door load - 20 kg

Protection - IP20

Triton marking explained:

Ali types - these are empty enclosures

Designation:

Width	x	Depth
x66	x	600 x 600 mm
x68	x	600 x 800 mm
x69	x	600 x 900 mm
x61	x	600 x 1000 mm
x60	x	600 x 1100 mm
x62	x	600 x 1200 mm
x86	x	800 x 600 mm
x88	x	800 x 800 mm
x89	x	800 x 900 mm
x81	x	800 x 1000 mm
x80	x	800 x 1100 mm
x82	x	800 x 1200 mm

The first digit in the designation of the modification indicates the height of the switchboard cabinet in U [unit]:

15 - 770 mm	27 - 1300 mm	42 - 1970 mm
18 - 900 mm	32 - 1525 mm	45 - 2105 mm
22 - 1080 mm	37 - 1750 mm	47 - 2194 mm

5. List of important parts of the technical documentation:

- Is stated in the Inspection folder No. 15.599.067

6. Validity Conditions

- The certificate shall apply only to its holder and products and production places mentioned therein.
- The transfer of the certificate by its owner to third parties is inadmissible as well as the use of certificate by third parties.
- TOV SOD Czech shall be notified forthwith of any product modifications compared to the certified specimen. This fact may cause the certificate continuation dependent on an additional conformity evaluation.
- TOV SOD Czech shall supervise the proper functioning of the Quality System at the manufacturer within a period of 1 year on the basis of a concluded contract about the controlling activity.
- The certificate can be renewed on request.
- The certificate shall only be reproduced complete including all the annexes.
- The right to use TOV SOD Czech certification mark was not established to the certificate.
- The certificate holder commits to keep records of all the relevant complaints concerning the conformity of the products with the requirements of regulations and standards and make those records available to the certification body TOV SOD Czech.
- Not specified items (advertising, use of certification mark and certificates) are governed by the General Conditions for Product Certification, as amended.

